



TYPE APPROVAL CERTIFICATE

N. **ELE070321CS003**

This is to certify that the product below is found to be in compliance with the applicable requirements of the RINA Type Approval system

Description	Fixed fire detection and fire alarm system: Smoke detectors with Heat detectors including Short circuit isolators
Type	MD9901 Smoke and Heat detector MD9901-EX Smoke and Heat detector (I.S.) In conjunction with fire detector bases: MD9900 BC; MD9900 BCI; MD9900 BS; MD9900 BSI; MD9900 BBZ; MD9900 BBZI; MD9900 BSZ; MD9900 BSZI; MD9900-BC-PT; MD9900-BCI-PT; MD9900-BBZ-PT; MD9900-BBZI-PT; MD9900-BS-PT; MD9900-BSI-PT; MD9900-BSZ-PT; MD9900-BSZI-PT
Applicant	MICRODATA DUE S.r.l. Via Greti del Vara 9 19020 Follo (SP) ITALY
Manufacturer	MICRODATA DUE S.r.l. Via Greti del Vara 9 19020 Follo (SP) ITALY
Testing Standards	EN 54-5:2017 incl. A1:2018; EN 54-7:2018 EN 54-17:2005 incl. AC:2007; IEC 60092-504:2016 ; IEC 60533:2015 IACS UR E10 Type Tests
Reference standards	SOLAS 74 Reg. II-2 /7; SOLAS 74 Reg. X/3; IMO Res. MSC.36(63)-(1994 HSC Code) 7; IMO Res. MSC.97(73)-(2000 HSC Code) 7; IMO Res. MSC.98(73)-(FSS Code) 9; IMO Res.MSC.391(95)-(IGF Code) 11; IMO MSC.1/Circ.1242
Issued at Genoa on June 21, 2021	This Certificate is valid until June 21, 2026

This Certificate consists of 3 pages

RINA Services S.p.A.

Luigi Benedetti





TYPE APPROVAL CERTIFICATE

N. **ELE070321CS003**

Products description:

MD 9901 Combined Smoke and Heat Detector

Analogue, Addressable microprocessor based photoelectric smoke detector including separate heat sensors.

A further sensor is exclusively used for analog measurement of temperature .

MD 9901 detector responds to para. 4.1 C) of CEA 4021 : July 2003 requirements

Temperature sensor complies with Class A1, B and C as defined on EN 54-5:2017 incl.A1:2018 requirements.

Reference documents

Microdata Due	ST24736 Rev. B	Technical specification;
Microdata Due	D24735 Rev. 0	Software description:
Microdata Due	D24731 Rev. F	Data sheet
Microdata Due	D36689 Rev. 0	Risk Assessment
Microdata Due	D36647 Rev. 0	Comparing Lexan 920 and Lexan 923 resin

Test Reports

BRE Laboratory	Report n. TE 220771, (25 /06/2005)	Env. / Performance
BRE Laboratory	Report n. TE 220771 SW, (25/04/2005)	Software Evaluation
Microdata Due	Report n. 1058 annex to IS-25793 rev. 0, (14/09/2005)	Functional Tests
Istituto Giordano Lab	Report n. 213254 , (30/06/2006)	Enclosure Protection
	IP 32 with detector bases MD9900-BC and MD9900-BCI	
	IP 65 with detector bases MD9900-BS and MD9900-BSI	
TesLab	Report n. 17B302E-b	(EMC) EN60092-504 (2016)
TesLab / Microdata Due	Report n. 0974-17 (28/11/2017) Functional test as procedure	IS37789 Rev.0 (EMC_IEC 60092-504:2016)
TesLab Laboratory	Report n. 214123E (2021-05-10) (EMC_EN50130-4: 2011+A1:2014)	

MD9901-EX IS Combined Smoke and Heat Detector

Analogue , Addressable Intrinsically Safe multicriteria fire detector, model **MD9901-EX**

Reference documents

Microdata Due	ST28999 Rev. B	Technical Specification
Microdata Due	D29009 Rev. E	Data sheet
Microdata Due	PRO076/10	Letter (10/05/2010)
Microdata Due	D24735 Rev. 0	Software description
Microdata Due	D36689 Rev.0	Risk Assessment

Safety references:

Certificate:	IMQ 09 ATEX 025 X (2017-01-24)
Marking:	II 2GD Ex ia IIC T5 Ga ; Ex ia IIC T100°C Da
Safety Standard:	EN60079-0:2012+A11:2013; EN60079-11:2012
Certification Authority:	IMQ S.P.A

Test reports:

Bre Global Laboratory	Report n. TE 255351 (14/04/2010)	Environmental / Performance
Bre Laboratory	Report n. TE220771SW (25/04/2005)	Software Evaluation
Istituto Giordano Lab.	Report n. 213254 (30/06/06)	Enclosure Protection
	IP65 with detector base MD9900-BS	
TesLab	Report n. 17B302E-c	(EMC) EN60092-504 (2016)
TesLab/ Microdata Due	Report n. 0974-17 (28/11/2017) Functional test as procedure	IS37789 Rev.0 (EMC_IEC 60092-504:2016)
TesLab Laboratory	Report n. 214123E (2021-05-10) (EMC_EN50130-4: 2011+A1:2014)	





TYPE APPROVAL CERTIFICATE

N. ELE070321CS003

Fire detector bases:

The following detector bases may be used in connection with MD9901 detectors

Models MD9900 BC or MD9900-BC-PT and MD9900 BCI or MD9900-BCI-PT detector bases (IP 32 in connection with MD9901 detectors) for false ceiling installation;

Models MD9900-BCI or MD9900-BCI-PT in addition contain a short circuit isolator

Models MD9900-BC-PT and MD9900-BCI-PT are suitable for connection to PTS Satellite

MD 9900 BS or MD9900-BS-PT and MD 9900-BSI or MD9900-BSI-PT detector bases: (IP65 in connection with the MD9901 detectors)

Models **MD9900-BSI or MD9900-BSI-PT** in addition contain a short circuit isolator

Models **MD9900-BS-PT and MD9900-BSI-PT are suitable for connection to PTS Satellite**

Reference documents:

<i>Microdata Due</i>	Technical specification n. ST21405 rev. C
<i>Microdata Due</i>	Data sheet n. D24729 Rev. E
<i>Microdata Due</i>	Data sheet n. D24730 Rev. E
<i>Microdata Due</i>	Functional Test Procedure n. D36618 Rev.0

Test reports:

<i>Ist. Giordano Lab.</i>	Report n. 213254, (30/06/2006) IP32 and IP65 protection with the MD9901 detectors
<i>BRE Laboratory</i>	Report n. TE213449/A, (03/10/2007) _ Environmental / Performance
<i>Microdata Due</i>	Test procedure n° IS 34434 _ report n. 822/14 testing on 16/05/2014
<i>Microdata Due</i>	Report n. 196 annex to IS-24743 Rev. 0, (22/02/2005) _ Functional Test
<i>Microdata Due</i>	Report n. D36618 Rev.0 (13/07/2016) - Functional Test Procedure
<i>Microdata Due</i>	Report n. 656/16 (02/08/2016)
<i>TesLab Laboratory</i>	Report n. 214123E (2021-05-10) (EMC_EN50130-4: 2011+A1:2014)

Fire detector bases with buzzer

The following detector bases may be used in connection with MD9901 detectors:

MD9900-BBZ and MD9900-BBZI or MD9900-BBZ-PT and MD9900-BBZI-PT fire detector bases (IP 32 in connection with the detector) include a Buzzer suitable for warning a fire alarm in accommodation spaces.

Models **MD9900-BBZI or MD9900-BBZI-PT** in addition contain a short circuit isolator

Models MD9900-BBZ-PT and MD9900-BBZI-PT are suitable for connection to PTS Satellite

MD9900-BSZ or MD9900-BSZ-PT and MD9900-BSZI or MD9900-BSZI -PT fire detector bases

(IP 65 in connection with the detector) include a Buzzer suitable for warning a fire alarm in a crew spaces.

Models **MD9900-BSZI or MD9900-BSZI -PT** in addition contain a short circuit isolator

Models MD9900-BSZ-PT and MD9900-BSZI -PT are suitable for connection to PTS Satellite

Reference documents:

<i>Microdata Due</i>	Data sheet n. D27897 Rev. E ; <i>Microdata Due</i> Data sheet n. D29020 Rev. B
<i>Microdata Due</i>	Report n. 474 annex to IS -28961 Rev. B, (12/11/2008) _ Functional tests
<i>Microdata Due</i>	Letter PRO051/09 (10/03/09)
<i>Microdata Due</i>	Functional Test Procedure n. D36618 Rev.0

Test reports:

<i>Istituto Giordano</i>	Report n. 213254, (30/06/2006)
<i>TesLab Laboratory</i>	Report n. 08C189F-3 (23/02/2009) _ Environmental / Performance
<i>Microdata Due</i>	Test Procedure n. IS 34434 _ report 822/14 testing on 16/05/2014
<i>Microdata Due</i>	Report n. D36618 Rev.0 (13/07/2016) - Functional Tests
<i>Microdata Due</i>	Report n. 656/16 (02/08/2016)
<i>TesLab Laboratory</i>	Report n. 214123E (2021-05-10) (EMC_EN50130-4: 2011+A1:2014)

